

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155386	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/09/2014
NAME OF PROVIDER OR SUPPLIER LAURELS OF DEKALB			STREET ADDRESS, CITY, STATE, ZIP CODE 520 W LIBERTY ST BUTLER, IN 46721		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/16/14 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a)</p> <p>Survey Date: 09/09/14</p> <p>Facility Number: 000574 Provider Number: 155386 AIM Number: 100266430</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Laurels of Dekalb was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original building consisting of the 100, 200, 300 and 400 halls, the main dining room and the service hall was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in in the corridors and areas open to the corridors. Battery operated smoke detectors were installed in the resident rooms. The facility has a capacity of 101 and had a census of 91 at the time of this survey.</p> <p>All areas where residents have customary access</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155386	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/09/2014
NAME OF PROVIDER OR SUPPLIER LAURELS OF DEKALB			STREET ADDRESS, CITY, STATE, ZIP CODE 520 W LIBERTY ST BUTLER, IN 46721		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 were sprinklered. The facility had a detached garage providing facility services including storage of beds, mattresses and snow blowers that was not sprinklered.	{K 000}			
{K 000}	Quality Review by Dennis Austill, Life Safety Code Specialist on 09/11/14. INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/16/14 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a) Survey Date: 09/09/14 Facility Number: 000574 Provider Number: 155386 AIM Number: 100266430 Surveyor: Amy Kelley, Life Safety Code Specialist At this Life Safety Code survey, Laurels of Dekalb was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The new section of the building consisting of the 300 hall Therapy gym was surveyed with Chapter 18, New Health Care Occupancies. This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155386	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/09/2014
NAME OF PROVIDER OR SUPPLIER LAURELS OF DEKALB			STREET ADDRESS, CITY, STATE, ZIP CODE 520 W LIBERTY ST BUTLER, IN 46721		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 2</p> <p>with smoke detection in in the corridors and areas open to the corridors. Battery operated smoke detectors were installed in the resident rooms. The facility has a capacity of 101 and had a census of 91 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. The facility had a detached garage providing facility services including storage of beds, mattresses and snow blowers that was not sprinklered.</p> <p>Quality Review by Dennis Austill, Life Safety Code Specialist on 09/11/14.</p>	{K 000}			